



Fiscal Services Department – Purchasing Division
12220 Fillmore Street - Room 331 - West Olive, Michigan 49460

Phone 616-738-4855
E-mail: purchasing.rfp@miottawa.org

ADDENDUM 2 - RFP 24-011 FIRE ALARM AND SUPPRESSION TESTING SERVICES

FEBRUARY 21, 2024

All Vendors:

The purpose of this addendum is to modify and/or clarify the above project. Information published here becomes part of the solicitation and is official and final. Vendors are to acknowledge the receipt of all addenda in their submission.

ITEM 1: REVISION:

Page 1, “RFP Deadline: By 2:00 PM (ET) Monday, February 26, 2024”

Revise to, “RFP Deadline: By 2:00 PM (ET) Thursday, February 29, 2024”

ITEM 2: VENDOR QUESTIONS RECEIVED AND ANSWERED:

Q1. Can the County supply equipment information for the following sites?

- 15600 68th Ave, Coopersville, MI 49404
- 16850 Comstock Ave, Grand Haven, MI 49417
- 6693 Roger Dr, Jenison, MI 49428
- 700 56th Ave, Zeeland, MI 49464
- 14053 Quincy, Holland, MI 49427
- 4529 48th Ave, Hudsonville, MI 49426

A2. Please consider the following for proposal pricing:

- 15600 68th, Coopersville has a Kidde IND-45 System
- 16850 Comstock, Grand Haven has a Kidde IND-45 System
- 6693 Roger, Jenison has a Kidde IND-45 System
- 700 56th, Zeeland has a a PyroChem Monarch PCI System
- 14053 Quincy, Holland has a PyroChem Monarch PCI System
- 4529 48th, Hudsonville has a PyroChem Monarch PCI System

Q2. Does the County require two (2) technicians for fire alarm panel testing (which is to be completed before or after normal business hours 8:00AM to 5:00PM)?

A2. It is preferable to have one technician on site since the contractor will need to be escorted by a facilities employee. The county will provide one person to escort while

doing the annual inspection. If the inspection can be done during the day the second technician will not have access to secure areas. Not all buildings have the fire alarm capability to start the inspection during business hours.